

# SCE Comments – PRR 1441

Submitted by: Wei Zhou, [Wei.Zhou@sce.com](mailto:Wei.Zhou@sce.com), 6/14/2022

Southern California Edison (SCE) provides these Recommendation comments on the California Independent System Operator's (CAISO) Proposed Revision Request (PRR)1441.<sup>1</sup>

SCE opposes this PRR, as the intention of this PRR is not clear and this PRR could lead to infeasible dispatch for inverter-based resources. SCE is concerned that the proposed change will require resources to follow the CAISO proposed ramp limitation that the resource cannot physically follow. For this reason, SCE recommends that this PRR be withdrawn and/or the CAISO provide further clarity on the intention of the PRR.

---

<sup>1</sup> <https://bpmcm.caiso.com/Pages/ViewPRR.aspx?PRRID=1441&IsDlg=0>